



Institute Code: E038

BLDE ASSOCIATION'S

Adarsh Nagar, Ashram Road, Vijayapur 586103, Karnataka, INDIA

Phone

: +91-8352-261120 (General Inquiry)

Mobile

: +91-9513398031 / 32 (Admissions)

Fax

: +91-8352-262945

Email

principal@bldeacet.ac.in | admissions@bldeacet.ac.in

Website

www.bldeacet.ac.in

Bideacetmedia : Facebook | Instagram | LinkedIN | twitter | YouTube

Ref. No.: BLDEACET / Engg / 739

1 2022 2023

Date: 10/08/2022

To,

The Principal,

Atal Bihari Vajpayee School

Vijayapur.

Subject: Test report of water sample supplied by you

Your Letter No: Nil, Dated: 08-08-2022.

Sir/Madam,

With reference to the above this is to inform you that the following tests have been conducted on water sample supplied by you, as per standard methods & the test report is as below.

WATER QUALITY ANALYSIS REPORT

Sl No	Characteristics	Water Sample	Limits for drinking water as per IS 10500-2012	
			Acceptable	Permissible
1	Turbidity, NTU	0	1	5
2	pН	6.60	6.5 – 8.5	No relaxation
3	TDS, mg/l	80	500	2000
4	Conductivity, µS	120	1000	
5	Total Hardness, mg/l	32	200	2500
6	Calcium, mg/l	6	75	600
7	Magnesium, mg/l	5	30	200
8	Chloride, mg/l	21		100
9	Alkalinity, mg/l		250	1000
10		24	200	600
10	Sulphate, mg/l	10	200	400

Remarks: For the characteristics checked, all the values are within the acceptable limits. Sample is safe and fit for drinking purpose.

Thanking You,

Yours sincerely,

HOD, Civil Engg. Dept.

rincipal

Department of Civil Engs. B.L.D.E.A's. V.P. Dr. P.G.H RLDEA's. College of Engg. & Tec' College of Engg. & Tech VIJAYAFUR-586101 DELAMADALE EL





Institute Code: E038

BLDE ASSOCIATION'S

Adarsh Nagar, Ashram Road, Vijayapur 586103, Karnataka, INDIA

Phone

: +91-8352-261120 (General Inquiry) : +91-9513398031 / 32 (Admissions)

Mobile Fax

: +91-8352-262945

Email

principal@bldeacet.ac.in | admissions@bldeacet.ac.in

Website

www.bldeacet.ac.in

Bideacetmedia : Facebook | Instagram | LinkedIN | twitter | YouTube

Ref. No.: BLDEACET / Engg / 739

1 2022 2023

Date: 10/08/2022

To,

The Principal,

Atal Bihari Vajpayee School

Vijayapur.

Subject: Test report of water sample supplied by you

Your Letter No: Nil, Dated: 08-08-2022.

Sir/Madam,

With reference to the above this is to inform you that the following tests have been conducted on water sample supplied by you, as per standard methods & the test report is as below.

WATER QUALITY ANALYSIS REPORT

Sl No	Characteristics	Water Sample	Limits for drinking water as per IS 10500-2012	
			Acceptable	Permissible
1	Turbidity, NTU	0	1	5
2	pH	6.60	6.5 – 8.5	No relaxation
3	TDS, mg/l	80	500	2000
4	Conductivity, µS	120	1000	
5	Total Hardness, mg/l	32	200	2500
6	Calcium, mg/l	6	75	600
7	Magnesium, mg/l	5		200
8	Chloride, mg/l	21	30	100
9	Alkalinity, mg/l		250	1000
		24	200	600
10	Sulphate, mg/l	10	200	400

Remarks: For the characteristics checked, all the values are within the acceptable limits. Sample is safe and fit for drinking purpose.

Thanking You,

Staff member in charge

HOD, Civil Engg. Dept.

Yours sincerely,

Principal

3.L.D.E.A's. V.P. Dr. P.G.H Department of Civil Engg. PLDEA's. College of Engg. & Tec' College of Engg. & Tech WITTENA DATES . FO VIJAYAPUR-586101